

HD688D(531-AB)							
DATE OF TESTED		2019/6/30					
APPLICABLE STANDARD		QB/T 2476-2000					
FINISH DESCRIPTION		青古	ANTIQUE BRASS				
mateiral grade		chemical composition					
REFERENCE		TENSILE STRENGTH Mpa	PB	N1	Cr	Cu	FE
BRASS		480	2.0~2.8	1	0	59	0.5
DESCRIPTIONS OF GOODS	TEST ITEMS	范围	STANDARD	TEST DATA		CONCLUSION	
				NO.1	NO.2		
Cylindrical lock	SURFACE ROUGHNESS	表面粗糙度	Ra≤6.3 μm	6.2	6.1	PASS	
	LATCH LATERAL STATIC LOAD	锁舌侧向静负荷	1500N	1500N	1500N	PASS	
	Handle the axial tensile force	执手轴向静拉力	1000N	1000N	1000N	PASS	
	Handle the radial static load	执手径向静载荷	800N	800N	800N	PASS	
	Key unlocking torque	钥匙开锁力矩	N.M≤1	1	1	PASS	
	Pull out key	钥匙拔出静拉力	N≤8	6	6.5	PASS	
PICTURE							